

## **Order No.:** 5LS44211EK | **GTIN (EAN):** 4039806171511 **Product description:** Mon21G1,TW,5x1.5<sup>2</sup>,L1.6m,term,5x2.5<sup>2</sup>



Monsun<sup>®</sup> 21 Gen.1, through-wiring, installation type: recessed, through-wiring set,5-core, 1.5mm<sup>2</sup>, cable length: 1,6m, terminal,5-pole, max. 2.5mm<sup>2</sup>, with protective earth, insulation class (complete): insulation class I (protective earthing), packaging unit: 1 piece

Wt. (kg): 0.2 GTIN (EAN): 4039806171511

It is mandatory that the assembly instructions must be observed when planning and installing the electrical installation (to be found at www.siteco.de) Tolerances related to thermal, electrical and photometric data according to IEC 62722 Issued 24.02.2023 - Modifications and errors subject to change - Ensure that you always use the latest version -

# ѕітесо

### Order No.: 5LS44211EK | GTIN (EAN): 4039806171511 Detailed technical description: Mon21G1,TW,5x1.5<sup>2</sup>,L1.6m,term,5x2.5<sup>2</sup>



#### Key data

- Product type: through-wiring
- Product name: Monsun® 21 Gen.1
- Order No.: 5LS44211EK

# Lighting technology | Lamps | Control gear

#### **Component 1**

#### Lamps:

 Supplement: for through-wiring from terminal of one luminaire to terminal of adjacent luminaire, through-wiring set includes heat-resistant single-core cable, terminals and mounting hardware, and PC conduit for connection of adjacent luminaires

#### **Certificates, Standards**

 Insulation class: insulation class I (protective earthing)

#### Mounting

- Mounting method, mounting location: recessed, in the luminaire
- Arrangement: continuous trunking
- Supplement: luminaires mounted end to end

#### **Dimensions, Weight**

- Weight: 0.2kg

It is mandatory that the assembly instructions must be observed when planning and installing the electrical installation (to be found at www.siteco.de) Tolerances related to thermal, electrical and photometric data according to IEC 62722 Issued 24.02.2023 - Modifications and errors subject to change - Ensure that you always use the latest version -