

Order No.: 59US1HXSPC1A | GTIN (EAN): 4058352363911

Product description: SConsens, PIR-sens, SI








SITECO ConnectSensor-Head PC1-S, slave, local control - self-sufficient standalone sensors, central control - connection to lighting or building management, dimmable, installation type: slip-in mounting, installation location: on interface, of plastic, protection rating (complete): IP54, certification: CE, VDE, 1 x PIR movement sensor, 1 x light sensor, packaging unit: 1 piece

Wt. (kg): 0.1

GTIN (EAN): 4058352363911





Order No.: 59US1HXSPC1A | GTIN (EAN): 4058352363911

Detailed technical description: SConsens, PIR-sens, SI



Key data

- System family: Siteco Connect 11, DALI-2, SITECO Connect, SITECO Connect 22
- Product type: sensor
- Product name: SITECO ConnectOrder No.: 59US1HXSPC1A

Lighting technology | Lamps | Control gear

Component 1

Operating device:

Control: DALI 2, dimmable

Certificates, Standards

- Protection rating: IP54
- Temperature range (operation): -20..+50°C
- Certification, designation: CE, VDE

Material, Colour

- housing: plastic, white
- Colour specification: white

Mounting

- Mounting method, mounting location: slip-in mounting, on interface
- Mounting height: 2.5..4m

Dimensions, Weight

Length: 95mmWidth: 95mmHeight: 65mmWeight: 0.1kg

Inputs

1x PIR movement sensor

- Connection: system connector
- Detection range: tangential max. ø40m
- Option: 11 detection levels, 1416 switching zones
- Feature: circular detection area


1x light sensor

 Feature: light sensor with 'local control' without function



Order No.: 59US1HXSPC1A | GTIN (EAN): 4058352363911

Dimensions: SConsens, PIR-sens, SI



Sensor Head PC1

Mh	R	Т
2m	ø = 11,4m	ø = 40m
3m	ø = 11.4m	ø = 40m

It is mandatory that the assembly instructions must be observed when planning and installing the electrical installation (to be found at www.siteco.de) Tolerances related to thermal, electrical and photometric data according to IEC 62722 Issued 09.04.2025 - Modifications and errors subject to change - Ensure that you always use the latest version -