

Order No.: 5LZ975200A | GTIN (EAN): 4069025427991

Product description: DA2rel.unit,DALI,rec



DALI2, relay unit, installation type: recessed, control gear: DALI 2, with terminal, 2-pole, max. 1.5mm², mains connection: 100..240V, AC, 50/60Hz, housing, housing, of plastic, grey, 2 part units, length: 110mm, width: 53mm, height: 65mm, relay unit, central control - connection to lighting or building management, equipment: master, dimmable, protection rating (complete): IP20, insulation class (complete): insulation class II (safety insulation), certification: CE, UKCA, permissible operating ambient temperature: 0..+45°C, packaging unit: 1 piece

IP 20 □ (∈

Wt. (kg): 0.2

GTIN (EAN): 4069025427991



Order No.: 5LZ975200A | GTIN (EAN): 4069025427991

Detailed technical description: DA2rel.unit,DALI,rec



Key data

 System family: Siteco Connect 11, SITECO Connect 21 4x relay contact

- Feature: 4 relays, 12A each

Product type: relay unitProduct name: DALI2Order No.: 5LZ975200A

Lighting technology | Lamps | Control gear

Component 1

Operating device:

- Control: DALI 2, dimmable

Certificates, Standards

- Protection rating: IP20
- Insulation class: insulation class II (safety insulation)
- Temperature range (operation): 0..+45°C
- Certification, designation: CE, UKCA

Material, Colour

- housing: plastic, grey, 2 part units
- housing: plastic, grey, 2 part units
- Colour specification: grey

Mounting

- Mounting method, mounting location: recessed, in an electrical distributor
- Supplement: only suitable for use in indoor areas

Electrical connection

- Connection: terminal, 2-pole, max.
- Nominal voltage: 100..240V, 50/60Hz,

Dimensions, Weight

Length: 110mmWidth: 53mmHeight: 65mmWeight: 0.2kg

Inputs

1x DALI

 Connection: plug-in terminal, 2-pole, max. 1.5mm²

Outputs

It is mandatory that the assembly instructions must be observed when planning and installing the electrical installation (to be found at www.siteco.com)
Tolerances related to thermal, electrical and photometric data according to IEC 62722
Issued 06.06.2025 - Modifications and errors subject to change - Ensure that you always use the latest version -